

To Whom It May Concern

No./Health/Hyg/PNP/2024/ 341

Date:- 29-4-2024

It is to inform you that **The Excel International School, V.P.O Dahar, Distt. Panipat** was inspected on **04/04/2024**. The sanitary and hygienic conditions in the School / Factory / Industry / Canteen / Hotel / bars / Godown / Shop / Restaurant is satisfactory.

This certificate is valid for one year from the date of issue.



Rajiv Singh
Dy. Civil Surgeon (Health)
Dy. Civil Surgeon (Panipat)
Panipat 4-4-2024



**PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, PANIPAT**

Website :- <https://phedharyana.gov.in/>

Memo No:- 387

Date:- 09/06/2023

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : PPT/00897/6/2023 / Private	Sample Details	Date & Time
	Collected By	
Sender : THE EXCEL INTERNATIONAL SCHOOL21974	Collection Date	07/06/2023 at 09:39
Location : , 95/2 , VILLAGE DAHAR , PANIPAT	Received at lab	07/06/2023 at 10:11
Sample Description : Drinking Water	Analysis Start Date	07/06/2023
Latitude / Longitude : 76.925245 / 29.322297	Analysis End Date	08/06/2023
	Sample Quantity	1ltr.

Test Result (As Per BIS 10500 :2012)


No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	458	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 1984 (RA 2017)
2	Total Hardness as CaCO3	276	200 mg/lit.	600 mg/lit.	IS 3025 (Part-21) : 2009 (RA 2019)
3	Calcium as Ca	40.08	75 mg/lit.	200 mg/lit.	IS 3025 (Part-40) : 1991 (RA 2019)
4	Magnesium as Mg	42.76	30 mg/lit.	100 mg/lit.	IS 3025 (Part-46) : 1994 (RA 2019)
5	Iron as Fe	0.0	1.0 mg/lit.	1.0 mg/lit.	IS 3025 (Part-53) : 2003 (RA 2019)
6	Chloride as Cl	18.49	250 mg/lit.	1000 mg/lit.	IS 3025 (Part-32) : 1986 (RA 2019)
7	Sulphate as So4	64	200 mg/lit.	400 mg/lit.	IS 3025 (Part-24) : 1986 (RA 2019)
8	Fluoride as F	0.38	1.0 mg/lit.	1.5 mg/lit.	APHA 4500-F--C
9	Nitrate as No3	18.7	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- D
10	pH @ 25°C	7.95	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 1983 (RA 2017)
11	Total Alkalinity	435	200 mg/lit.	600 mg/lit.	IS 3025 (Part-23) : 1986 (RA 2019)
12	Color	1	5 Hazen Units	15 Hazen Units	IS 3025 (Part-4) : 1983 (RA 2017)
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
14	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2017)
15	Turbidity	0.20	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2017)

Remarks :-

- The Results Given above are related to the sample as received and tested in PHED PANIPAT Lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.
- The test samples meant for chemical analysis will be disposed after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

For The Excel International School

For The Excel International School



Shanky
Manager

Shanky
Manager



**PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY , PANIPAT**

D
na

Website :- <https://phedharyana.gov.in/>

No:- 387


Date:- 09/06/2023


Subject: Physical / Chemical Examination Report of Water Sample

Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
On the tested parameters, the water sample is found "POTABLE"



Sample analyzed by :


SATISH KUMAR CHEMIST
DISTRICT WATER TESTING
LABORATORY, PANIPAT
email:-chemist.panipat@phedharyana.gov.in


Executive Engineer
Public Health Engineering
Division No. 1, Panipat

For The Excel International School

Manager



संशोधन विभाग
जि.प.ई.ओ. सि.वि.नं. 3-10-2018 स
29-10-2017 तक रामनिवाह पुणे रेजि.नं.
स.सि.के.प.स. परीक्षण रिपोर्ट पत्रिका

For The Excel International School

Manager

For The Excel International School

